

# Kerala Engineering & Construction Co.,

## ENGINEERS & ARCHITECTS

(Estd - 1950)

Founder

**C.V. APPA**, A.M.I.S.E  
L.B.E

Consulting Engineer and Designer

Approved Member for issuing Stability  
Certificate to Factory Building under  
Factories Act and Valuer for Banks. } (No. T.R. 16685/73)

Consulting Engineer, Valuer - IT, Bank, Registration Dept.  
**C.V. SUDEVAN**, BSc, A.M.I.S.E, M.I.S.E

Govt. Reg. Engineer A-grade  
Reg. No. A1-13983/02/1461/EA  
Govt. of Kerala Dept. of Municipal Administration

Head Office  
Old Caltex Jn.  
Sub Office  
Trade Centre,  
Nr. Sub Registrar Office  
Kannur - 670 002

Mob : 9846423306  
9496086770  
9847427133

Off : 0497 2766770

E-mail:keralaengineeringknn@gmail.com

**Branches**  
TELLICHERRY  
CALICUT & KASARAGOD

Ref.No. *K.E.C-C/6242/2020-21*

Date : *19.09.2020*

### CERTIFICATE OF STABILITY AND FITNESS

This is to certify that I have inspected the site of the existing School building named as **Kasturba Public School (Senior Secondary)**, Owned by **C.K Sarojam Thamburatti**, situated in **R.S No.45/9**, at **Chirakkal Amsom- Despm, Chirakkal Panchayath, Kannur Taluk, District, Kerala State** and examined the various parts including the foundation as shown in the complete plan approved by **Chirakkal Grama Panchayath**.

Permit Approved No. **A3-3311/13**, dated **26/03/2013**.

Building No. **C.P III 237 A, 237 B, 237 C**.

The sub soil is ordinary and laterite soft rock seen at random 2.50 m below the ground level. R.C.C Column start from 2.50 m below the ground level. R.C.C framed structure building (G+2) Floors. R.C.C piles and plinth beams has been provided to the foundation for strengthening the structure. Column size 40X20 cm, Beam 50X20 cm, Verandah pillars 25X20 slab thickness 12 cm etc., are provided. I am of opinion that the existing school building has constructed in accordance with the plan approved by the Panchayath with required foundation inconformity with requirement of public work department. It is structurally sound. The building as a whole is structurally stable and well maintained. Plinth are G.F-159.65 m2, F.F-186.17 m2, S.F-186.17 m2. The building is fit for functioning educational purposes.

  
**MANAGER**  
**Kasturba Public School**  
Aff. No. 930054  
Chirakkal PO, Kannur - 670011

**Er. C.V. SUDEVAN**, B. Sc, A.M.I.S.E, M.I.S.E  
Consulting Engineer, Designer & Valuer  
Reg. Engineer 'A' No. A1-13983/02/1461/EA  
Govt. of Kerala, Dept. of Municipal Administration  
**KERALA ENGINEERING & CONSTRUCTION CO.**  
(Founder: Late C.V. APPA Engineer) Estd 1950  
(H. O. Old Caltex Junction)  
Trade Centre, 1<sup>st</sup> Floor, Room No: 12 CB  
Near Sub Registrar Office, KANNUR - 670 002

  
**PRINCIPAL**  
**KASTURBA PUBLIC SCHOOL**  
CHIRAKKAL P. O.  
KANNUR-670 011